



Head Office Address :

Panta House, valley Road Msida, MSD9024 Malta.

Telephone : (00356) 21441361 Fax : (00356) 21446462

E-mail: cth@pantalesco.com

Company Address In Libya :

P.O.Box :601 Tripoli

Telephone : 00218 21 716 4862 / 00218 92 587 6326

E-mail: pantalesco@gmail.com

5th April 2014

Golden Gate Manufacturer

Ref. PCO-14/678

For the attention of: **Emad Zawia – General Manager**

Hydrostatic Pressure Test of PVC Pipes

Dear Sir,

Subsequent to your instructions, we now inform you that we have carried out a Hydrostatic Pressure Test on the Schedule 40 PVC Pipes you have supplied from your factory.

We kindly ask you to refer to the following test information:

Hydrostatic Pressure Test Data

- Test Medium: 6" PVC Schedule 40 Pipes
- Test Pressure: 12Bar
- Test Duration: 12 Hours
- Test Result: Passed, no defects noted on pipe during or after test

Assuring you of our continued co-operation at all times, meanwhile, we remain,

Yours faithfully,
PANTA CONTRACTING LIMITED (Libya Branch)


Adrian Borg
General Manager